

PHOTOMETRIC TEST REPORT

DECOR PRO ROUND
ADJUSTABLE - TEXTURED WHITE
- 4002771

astro

DECOR PRO ROUND ADJUSTABLE -

astro


LIGHT EFFICIENCY:



LIGHT QUALITY:



COLOR TEMPERATURE:



OUTPUT: 1252 lm

PEAK: 2312 cd

POWER: 11.7 W

PF: 0.95




Tracking number: [n/a](#)

Product name:
Decor Pro Round Adjustable - Textured
White - 4002771

Item number:
DRA-TW-HE27G1-50G1-X-D1


Date and time:
19/12/2024 16:05:50

Description:
IP20 LED Downlight




CIE 1931
x: 0.453
y: 0.411



SPECTRA



POWER





COLOR DETAILS



TM30: 93.2

CRI: 96.0 (R1-R8)



CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
98.4	98.0	96.3	97.8	98.0	97.1	94.2	88.2	70.7	93.6	95.8	90.8	97.9	96.4	93.8


TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
92.5	95.8	93.2	96.0	95.2	93.5	95.3	95.9	97.2	96.0	94.8	87.6	85.2	86.6	93.3	86.1

CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
87.6	92.4	93.0	95.3	94.7	92.4	93.9	96.2	97.8	96.1	96.0	96.3	96.7	90.8	88.9

CQS: 93.0









COLOR PARAMETERS

Color temperature	Color rendering index	Red component	Color fidelity	Color gamut	Color quality scale	Color coordinate cie 1931	Color coordinate cie 1931	Color coordinate	Color coordinate	Color deviation from black body
CCT	CRI	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
2810 K	96.0	70.7	93.2	100.7	93.0	0.453	0.411	0.258	0.351	0.0008


Rf 93.2
Fidelity index Rf

Rg 100.7
Gammut index Rg

Hue Bin	R _f	Graphic shifts (%)	
		Chroma	Hue
1	92	-4%	-1%
2	96	-2%	1%
3	93	-1%	3%
4	96	0%	1%
5	95	1%	4%
6	94	3%	2%
7	95	1%	-2%
8	96	2%	-1%
9	97	0%	-1%
10	96	0%	1%
11	95	1%	3%
12	88	5%	-4%
13	85	3%	-11%
14	87	2%	-10%
15	93	-1%	-4%
16	86	-4%	-10%



BEAM DETAILS



Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3.3ft	6.6ft	9.8ft	13.1ft	16.4ft	19.7ft	23ft	26.2ft	29.5ft	32.8ft	36.1ft	39.4ft	42.7ft	45.9ft	49.2ft	52.5ft	55.8ft	59.1ft	62.3ft	65.6ft
2312lx	578lx	257lx	144lx	92lx	64lx	47lx	36lx	29lx	23lx	19lx	16lx	14lx	12lx	10lx	9lx	8lx	7lx	6lx	6lx
214.7fcd	53.7fcd	23.9fcd	13.4fcd	8.6fcd	6fcd	4.4fcd	3.4fcd	2.7fcd	2.1fcd	1.8fcd	1.5fcd	1.3fcd	1.1fcd	1fcd	0.8fcd	0.7fcd	0.7fcd	0.6fcd	0.5fcd

Intensities in 0° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
2312	2312	2298	2265	2214	2142	2048	1931	1792	1628	1444	1241	1026	811	610	438	300	191	112	57
100%	100%	99%	98%	96%	93%	89%	84%	78%	70%	62%	54%	44%	35%	26%	19%	13%	8%	5%	2%

Intensities in 90° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
2312	2312	2298	2265	2214	2142	2048	1931	1792	1628	1444	1241	1026	811	610	438	300	191	112	57
100%	100%	99%	98%	96%	93%	89%	84%	78%	70%	62%	54%	44%	35%	26%	19%	13%	8%	5%	2%

Intensities in 180° c-plane


0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
2312	2312	2298	2265	2214	2142	2048	1931	1792	1628	1444	1241	1026	811	610	438	300	191	112	57
100%	100%	99%	98%	96%	93%	89%	84%	78%	70%	62%	54%	44%	35%	26%	19%	13%	8%	5%	2%

Intensities in 270° c-plane


0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
2312	2312	2298	2265	2214	2142	2048	1931	1792	1628	1444	1241	1026	811	610	438	300	191	112	57
100%	100%	99%	98%	96%	93%	89%	84%	78%	70%	62%	54%	44%	35%	26%	19%	13%	8%	5%	2%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
45.6°	66.5°	75.9°	99.8%	99.6%

ISO CANDELA DIAGRAM



ISO LUX DIAGRAM



UGR

GLARE EVALUATION ACCORDING TO UGR


p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	18.0	18.5	18.0	18.7	18.9	18.0	18.5	18.0	18.7	18.9
	3H	17.6	18.3	18.0	18.5	18.7	17.6	18.3	18.0	18.5	18.7
	4H	17.6	18.2	18.0	18.4	18.7	17.6	18.2	18.0	18.4	18.7
	6H	17.6	18.1	17.9	18.4	18.7	17.6	18.1	17.9	18.4	18.7
	8H	17.5	18.0	17.8	18.3	18.7	17.5	18.0	17.8	18.3	18.7
	12H	17.5	17.9	17.8	18.3	18.7	17.5	17.9	17.8	18.3	18.7
4H	2H	17.6	18.2	18.0	18.4	18.7	17.6	18.2	18.0	18.4	18.7
	3H	17.5	17.9	17.8	18.3	18.7	17.5	17.9	17.8	18.3	18.7
	4H	17.3	17.8	17.7	18.2	18.7	17.3	17.8	17.7	18.2	18.7
	6H	17.2	17.7	17.7	18.1	18.4	17.2	17.7	17.7	18.1	18.4
	8H	17.2	17.6	17.7	18.0	18.3	17.2	17.6	17.7	18.0	18.3
	12H	17.1	17.5	17.6	17.9	18.3	17.1	17.5	17.6	17.9	18.3
8H	4H	17.2	17.6	17.7	18.0	18.3	17.2	17.6	17.7	18.0	18.3
	6H	17.1	17.4	17.6	17.9	18.4	17.1	17.4	17.6	17.9	18.4
	8H	17.1	17.3	17.6	17.8	18.5	17.1	17.3	17.6	17.8	18.5
	12H	17.0	17.2	17.6	17.7	18.3	17.0	17.2	17.6	17.7	18.3
12H	4H	17.1	17.5	17.6	17.9	18.3	17.1	17.5	17.6	17.9	18.3
	6H	17.1	17.3	17.6	17.8	18.5	17.1	17.3	17.6	17.8	18.5
	8H	17.0	17.2	17.6	17.7	18.3	17.0	17.2	17.6	17.7	18.3
Variation of the observer position for the luminaire distance S											
S = 1.0H		6.6 / -20.1					6.6 / -20.1				
S = 1.5H		9.4 / -21.8					9.4 / -21.8				
S = 2.0H		11.4 / -22.7					11.4 / -22.7				
Standard table		n/a					n/a				
Correction summand		n/a					n/a				
Corrected glare indices referring to 1252 lm total luminous flux											

COEFFICIENTS OF UTILIZATION

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	112	110	108	112	110	108	106	106	104	103	102	101	100	99	98	97	95
2	110	106	102	99	108	104	101	98	101	98	96	98	96	94	95	93	92	90
3	105	100	96	92	103	99	95	92	96	93	90	94	91	89	91	89	87	86
4	101	95	90	87	99	94	89	86	92	88	85	90	87	84	88	85	83	82
5	97	90	85	82	96	89	85	81	87	84	81	86	82	80	84	81	79	78
6	93	86	81	77	92	85	80	77	84	80	76	82	79	76	81	78	75	74
7	90	82	77	73	88	81	77	73	80	76	73	79	75	72	78	75	72	71
8	86	78	73	70	85	78	73	70	77	72	69	76	72	69	75	71	69	68
9	83	75	70	67	82	74	70	66	74	69	66	73	69	66	72	68	66	65
10	80	72	67	64	79	71	67	64	71	66	63	70	66	63	69	66	63	62

LAMPS (number of lamps)

LUMINAIRE BUDGETARY DIAGRAM




ZONAL LUMEN SUMMARY

0°-10°	10°-20°	20°-30°	30°-40°	40°-50°	50°-60°	60°-70°	70°-80°	80°-90°
213 lm	510 lm	413 lm	106 lm	5.06 lm	1.16 lm	0.281 lm	0.109 lm	0.112 lm
90°-100°	100°-110°	110°-120°	120°-130°	130°-140°	140°-150°	150°-160°	160°-170°	170°-180°
0.123 lm	0.112 lm	0.117 lm	0.189 lm	0.344 lm	0.547 lm	0.576 lm	0.391 lm	0.117 lm


FLICKER CURVE (COMPLETE SAMPLED)



FLICKER FRAME (FRAME OF ONE FLICKER



FLICKER FFT (FREQUENCY SCOPE OF FLICKER



FLICKER RESULTS:

Flicker frequency:	n/a Hz
Flicker index:	n/a
Flicker percentage:	n/a %
SVM: (Visual flicker)	n/a

FLICKER CONDITIONS:

Sample rate:	n/a samples/second
--------------	--------------------